GOVERNMENT OF TELANGANA STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT

 From:
 To:

 District Fire Officer
 The Addl.Collector,

 Nizamabad Division
 Nizamabad District.

Rc.No.686/A2/2021 Dated.15-04-2021

Sir,

- Sub: -Telangana State Disaster Response and Fire Services Department-C/R- Nizamabad Division- Issuance of affiliation/recognition to Kendriya Vidyalaya Nizamabad DIET College Premises, Nagaram, Chakradhar Nagar, Nizamabad town & District-Inspection report- Submitted- Regarding.
- Ref: -1. G.O.Ms.No.56 HOME (SERICES-IV) DEPARTMENT Date.26-07-2019 2. Letter Dated.08-04-2021 of the Pricipal, Kendriya Vidyalaya, Nizamabad.

 $\diamond \diamond \diamond$

In obedience to the references cited above, we have inspected the Non Multi Storeyed building of Kendriya Vidyalaya Nizamabad DIET College Premises, Nagaram, Chakradhar Nagar, Nizamabad town & District for the construction of Ground + 01 upper floor with a height of 07.32 Mtrs. for Educational -B1.

We have inspected the above building and it was constructed before 2009. The management has installed all fire fighting system as per reference 1st cited.

Hence, there is No objection from this office for issuance of affiliation/recognition to Kendriya Vidyalaya, Nizamabad town & District.


Yours faithfully,

(G.Murali Manohar Reddy) District Fire Officer, Nizamabad Division.

Copy to the Station Fire Officer, Nizamabad. Copy to the Pricipal, Kendriya Vidyalaya, Nizamabad.

CITETE / PRIMCIPAL CITE RELATE I KE SKIVA VIDYALAYA CITE RELATE I KE SKIVA VIDYALAYA CITETER / NIZAMABAD

Rc. No. 368 /A2/2021



Office of the District Fire Officer Nizamabad Division Dated. 02-03-2021

Po The Additional Collector, Nizamabad.

Sir.

Sub: - Telangana State Disaster Response and Fire Services Department - C/R-Nizamabad Division- Kendriya Vidyalaya, Nizamabad – Inspection Report– Submitted- Regarding.

Ref: - 1) Lr.No. A2/1017/2019 Dated 11-02-2021 of the Additional Collector, Nizamabad.

2) Inspection Report of the Non Multi Storeyed Building Inspection Committee Dated 27-02-2021.

aaaaa

In compliance to the instructions issued by the Additional Collector, Nizamabad vide reference 1st cited above, and as per the instructions of the undersigned the Non Multi Storeyed Building Inspection Committee has inspected the premises of Kendriya Vidyalaya, Nizamabad and submitted the Inspection report vide reference 3rd cited above duly submitting the report on fire safety measures and submitted the following remarks.

The Non Multi Storeyed Building Inspection Committee has observed that the Kendriya Vidyalaya building was initially used for Diet College from 06-12-1992 upto a period of 2018 and the said Kendriya Vidyalaya has been started in the year 2018 and further submitted that the management has also not provided the fire safety measures which are required as per Part-IV and Life Safety of NBC 2016 except Portable Fire Extinguishers.

It is further submitted that as per G.O.Ms.No. 56, Home (Services-IV) Department Dated 26-07-2019 (copy enclosed), all schools constructed before the Hon'ble Supreme Court Order dated 13-04-2009 shall follow the fire safety norms of National Building Code of India.

The management is requested to provide the fire safety measures as per NBC-2016 and submit the same to the concerned authorities duly marking a copy to this office.

Submitted for favour of kind information.

Yours faithfully,

(G.Murali Manohar Reddy) District Fire Officer, Nizamabad Division.

Encl: (As above)

Copy to the District Revenue Officer, Nizamabad for kind information.

ANNEXURE-I

(Annexure to G.O.Ms.No.56, Horne (Ser.IV) Department, Dated: 26.07.2019) Instructions to be

followed for schools existing before 13.04.2009:

SELF CERTIFICATION FORM

Self Certification of Fire Safety Measures by School Management :

I) General Information for School Buildings of all categories i.e., A, B, C & D.

SI.		
No.	Details	
1	Date of the opening of the school building	23.07.2018
2	Name of the applicant	PRINCIPAL
3	Name and address of the School	KENDRIYA VIDYALAYA NIZAMABAD, DIET COLLEGE PREMISES, NAGARAM, CHAKRADHAR NAGAR, NIZAMABAD-503 003.
4	Telephone Number and email of the applicant	(+91)-9491256605 kvnizamabad@gmail.com
5	Height of the building(in metes)	7.32 Meters
6	No of floors	G+1
7	Abutting Road width (in meters)	30.48 Meters
8	Built-up area of each floor in Sq.Nltrs Stilt Ground Floor 1 Floor 2	955.88 Sq.Mtrs 479.52 Sq.Mtrs NA
9	Number of Staircases Staircase 1 (width in meters) Staircase 2 (width in meters)	1.46 Meters
10		3.46 Meters & 1.40 Meters
11	Open Spaces North (width in meters) East (width in meters) West (width in meters) South (width in meters)	35.25 Meters 30.43 Meters

Signature With Darrad DYALAYA

School Buildings with Ground Floor or Ground plus one upper floor.

SI. No	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided Yes/ No
1.	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 Square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius.	08	YES
2.	Automatic Sprinkler S y s t e m (IS 15105:2002). The IS standard may be downloaded from www. <u>https://bis.gov.in</u>	To be installed in basement. If area of basement exceeds 200 square meters	NA	NA

Note: For Ground +1 floor buildings, if the floor area in a single floor Is more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal Steel structure.

Ca-20 21 Station Fire Officer Ass Fire Station, NIZAMABAD. Nizamabad.

Signature with date of School authority and Seal Surent / PRINCIPAL Scill Raina / KENDRYA VIDYALAYA Rainiag / NIZAMABAD Contd/-2