

ANNEXURE-I

(Annexure to G.O.Ms.No.56, Horne (Ser.IV) Department, Dated: 26.07.2019) Instructions to be followed for schools existing before 13.04.2009:

SELF CERTIFICATION FORM

Self Certification of Fire Safety Measures by School Management :

I) General Information for School Buildings of all categories i.e., A, B, C & D.

Sl. No.	Details	
1	Date of the opening of the school building	23.07.2018
2	Name of the applicant	PRINCIPAL
3	Name and address of the School	KENDRIYA VIDYALAYA NIZAMABAD, DIET COLLEGE PREMISES, NAGARAM, CHAKRADHAR NAGAR, NIZAMABAD-503 003.
4	Telephone Number and email of the applicant	(+91)-9491256605 kvnizamabad@gmail.com
5	Height of the building(in metes)	7.32 Meters
6	No of floors	G+1
7	Abutting Road width (in meters)	30.48 Meters
8	Built-up area of each floor in Sq.Nltrs Stilt Ground ----- Floor 1 ----- Floor 2 -----	955.88 Sq.Mtrs 479.52 Sq.Mtrs NA
9	Number of Staircases Staircase 1 ----- (width in meters) Staircase 2 ----- (width in meters)	1.46 Meters 1.46 Meters
10	Width of each Staircase	3.46 Meters & 1.40 Meters
11	Open Spaces North ----- (width in meters) East ----- (width in meters) West ----- (width in meters) South ----- (width in meters)	35.50 Meters 35.25 Meters 30.43 Meters 20.40 Meters

Signature with date of School authority and Seal
KENDRIYA VIDYALAYA
NIZAMABAD

School Buildings with Ground Floor or Ground plus one upper floor.

Sl. No	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided
				Yes/ No
1.	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 Square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius.	08	YES
2.	Automatic Sprinkler System (IS 15105:2002). The IS standard may be downloaded from www.https://bis.gov.in	To be installed in basement. If area of basement exceeds 200 square meters	NA	NA

Note: For Ground +1 floor buildings, if the floor area in a single floor is more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal Steel structure.

Station Fire Officer
Fire Station, NIZAMABAD.

Asst. District Fire Officer
Nizamabad.

Signature with date of School authority and Seal
KENDRIYA VIDYALAYA
NIZAMABAD